



1.1 **Municipal Bylaw**

Municipal By-Law No. 4111-1988

Section XIV: Underground Flammable and Combustible Liquid Storage Tanks

86. When underground storage tanks will not be reused, or have been out of service for three years, whichever comes first.

- The authority having jurisdiction shall be notified in writing;
- Flammable and combustible liquids shall be removed from the storage tanks, connected piping and dispensing equipment;
- Storage tanks shall be removed from the ground and purged of vapors;
- The piping shall be removed from the ground or shall be purged of flammable liquids and vapor, and the ends of the piping shall be permanently sealed by capping or plugging, and
- If the soil around and under the storage tank is contaminated with liquid, it shall be replaced with clean fill to a degree acceptable to the authority having jurisdiction.

87. All used tanks removed from the ground shall be destroyed or disposed of in a manner approved by an officer.