

TO: City Of Maple Ridge
ATTN: Roy Skeet (Aplin & Martin Consultants Ltd.)
PHONE:
PROJECT: City Of Maple Ridge Downtown Enhancement Project
EBC RFI NO.: 8
DATE: 30-Nov-18

PAY ITEM: Concrete Curbs, Sidewalks, & Median Infill
DWG REF:
SPEC REF: MMCD 03 30 20 Sections 3.14 & 3.15

DESCRIPTION OF INFORMATION REQUESTED

BA Blacktop / Eurovia BC would like to draw to the client's attention that, following the contractual time period for curing and protection, damage can be caused to freshly placed concrete through the application of anti-icing brines, salts, and sprays.

Application of de-icing products can result in the following:

1. Accelerated wear
2. Scaling
3. Reinforcing steel corrosion
4. Weakening of structure

BAB/EBC request that notification be provided to property owners, maintenance departments, and stakeholders who may be in a position to contribute to the application of de-icing products.

Following the completion of the curing & protection time period, BAB/EBC will not be responsible for damage resulting from the application of de-icing products.

Example of Typical Salt Damage:

