

FACILITY NAME: <i>Whinnock Lake Community Hall W.S.</i>		INSPECTION DATE (yyyy/mm/dd): <i>2024/June/14</i>	TIME SPENT: <i>1.0</i>
FACILITY ADDRESS: <i>27871 - 113 Ave., Maple Ridge</i>		NEXT INSPECTION DATE (yyyy/mm/dd): <i>2025/June/15</i>	
☐ NEW PERSON IN CHARGE: <i>Michael Albrecht</i>		☐ New Tel: <i>604 363-6671</i> ☐ New Fax: ()	
☐ NEW EMERGENCY CONTACT: <i>City of Maple Ridge</i>		☐ New Tel: <i>604-463-5221</i> ☐ New Fax: ()	
FACILITY TYPE: ☐ WS1 (300+ connections) ☒ WS4 (1 public connection) ☐ WS2 (15 - 300 connections) ☐ WS9 (other) ☐ WS3 (2 - 14 connections)		INSPECTION TYPE: ☐ Initial ☐ Consultation ☐ Follow Up to Lab Report ☒ Routine ☐ Sampling ☐ Water Quality Complaint ☐ Follow Up ☐ Investigation ☐ Water Borne Illness Complaint	
ACTION TAKEN: ADMINISTRATIVE ☒ Information Provided ☐ No Action Required ☐ Permit Issued ☐ Rescind Public Notification		OTHER INFORMATION: (complete for Routine Inspection) EOCIP (operator certification) ☐ Yes ☐ No ☒ N/A Acceptable SWS Training ☒ Yes ☐ No ☐ N/A ERCP (emergency plan) ☒ Yes ☐ No ☐ N/A Annual Report Provided to Users ☒ Yes ☐ No ☐ N/A	
HAZARD RATING FOR YOUR FACILITY: ☐ High ☐ Moderate ☒ Low			

Follow Up to "Critical" Violations Noted on Previous Inspections (if applicable)

Code	Corrected?	Code	Corrected?
	☐ Yes ☐ No		☐ Yes ☐ No
	☐ Yes ☐ No		☐ Yes ☐ No
	☐ Yes ☐ No		☐ Yes ☐ No

Code	Explanation of Violations, Recommendations or Comments	(✓) Corrected During Insp.	Date To Be Corrected By
	<i>Review & update of ERCP discussed during inspection.</i> <i>Good stick up of well head & locked cap.</i> <i>Drinking water quality & sampling frequency in compliance.</i> <i>Drinking water system well maintained & operational.</i> <i>Analyses for chemical & physical health-based parameters completed May 29, 2024 and water quality is in compliance with health based guidelines.</i> <i>Treatment system (UV unit, filters, etc.) maintained. Filters changed 2x/month.</i>		

RECEIVED BY (Signature): <i>Michael Albrecht</i>	EHO (Signature): <i>[Signature]</i>
PRINTED NAME: <i>Michael Albrecht</i>	EHO PRINTED NAME: <i>[Name]</i>